

RESOLUTION

No. 25-6

A RESOLUTION AMENDING RESOLUTION NO. 25-4 TO MODIFY THE ADOPTED LOCAL LIMITS FOR DINITROTOLUENE

WHEREAS, the Washington-East Washington Joint Authority (“Authority”) adopted Resolution No. 25-4 on June 16, 2025, establishing revised local limits pursuant to the requirements of the Clean Water Act (33 U.S.C. § 1251 et seq.), the Pennsylvania Clean Streams Law (35 P.S. § 691.1 et seq.), 40 C.F.R. Part 403, and NPDES Permit No. PA0026212; and

WHEREAS, Attachment A to Resolution No. 25-4 included separate maximum allowable industrial load (MAIL) values for 2,4-dinitrotoluene, 2,6-dinitrotoluene, and dinitrotoluene (total); and

WHEREAS, the Authority subsequently received comments from a permitted Industrial User noting that the mass loading limit for total dinitrotoluene in Attachment A was lower than the limits established for the individual isomers 2,4-dinitrotoluene and 2,6-dinitrotoluene, creating an inconsistency in the adopted local limits; and

WHEREAS, following consultation with the United States Environmental Protection Agency, the Authority has confirmed that it is appropriate to remove the isomer-specific limits for 2,4-dinitrotoluene and 2,6-dinitrotoluene while retaining the limit for total dinitrotoluene, consistent with the Authority’s obligations under its NPDES Permit;

NOW, THEREFORE, BE IT RESOLVED by the Board of Directors of the Washington-East Washington Joint Authority that:

1. Resolution No. 25-4 is hereby amended to delete the separate MAIL values for 2,4-dinitrotoluene and 2,6-dinitrotoluene from Attachment A.
2. The MAIL value for dinitrotoluene (total) as adopted in Resolution No. 25-4 shall remain in full force and effect.
3. The Authority shall implement and enforce this amended local limit in accordance with the Clean Water Act, the Pennsylvania Clean Streams Law, 40 C.F.R. Part 403, and the conditions of NPDES Permit No. PA0026212.
4. Except as expressly modified herein, all other provisions of Resolution No. 25-4 shall remain unchanged and in full effect.

RESOLVED AND ADOPTED this 25 day of August, 2025, by the Board of Directors of the Washington-East Washington Joint Authority.

Attest: Jeffrey D Bull
Secretary

Signature: [Signature]
Chairman

SEAL

Resolution 25-5

Attachment A

Maximum Allowance Industrial Load Proposed for Adoption¹

Parameter	Existing Headworks Industrial Allowance (lb./day)	Headworks Industrial Allowance ³ (lb./day)	Basis of Limitation
2,4-Dinitrotoluene	Not Applicable²	0.0514	Water Quality
2,6-Dinitrotoluene	Not Applicable²	112.5006	Water Quality
Arsenic	0.6671	0.5732	Water Quality
Cadmium	0.0391	0.0391	Existing
Chloride	Not Applicable ²	9032.9255	Water Quality
Chlorodibromomethane	Not Applicable ²	0.0406	Water Quality
Chloroform	Not Applicable ²	0.4512	Water Quality
Chromium	13.4007	13.4007	Existing
Copper	3.4449	2.8611	Sludge
Cyanide	0.3174	0.3174	Existing
Dichlorobromomethane	Not Applicable ²	0.0547	Water Quality
Dinitrotoluene	Not Applicable ²	0.0049	Water Quality
Free Cyanide	Not Applicable ²	0.1649	Water Quality
Lead	1.0719	0.7135	Sludge
Mercury	.0037	0.002	Water Quality
Molybdenum	Not Applicable ²	1.1897	Sludge
Nickel	6.1490	2.2352	Sludge
Selenium	2.0683	0.3365	Water Quality
Silver	3.0307	3.0307	Existing
Sulfate	Not Applicable ²	7130.6701	Water Quality
Total Dissolved Solids	Not Applicable ²	4115.0586	Water Quality
Zinc	2.3684	2.3684	Existing

Notes:

1. Values in **BOLD** are recommended for adoption no later than September 6, 2025.
2. Not Applicable - indicates that this pollutant parameter is a new limit assessed for the most recent Headworks Loading Analysis evaluation and required by USEPA and adoption.
3. Headworks Industrial Allowance – Total maximum mass of pollutant for aggregate IU permits and reserve.