

The Washington-East Washington Joint Authority

Development Information Form

Section A: Wastewater Estimations

Project Name _____

Project Address _____

Parcel ID Number(s) _____

Proposed Flow – Peak Daily (gpd) _____

Existing Flow – Peak Daily (gpd) _____

Net Flow – Peak Daily (gpd) _____

Required Submission Materials:

- Wastewater Estimation Calculations
 - Must include supporting documentation for the peak daily flow estimates
 - Estimations shall be based on the type of use (e.g. single-family dwelling, apartment, hotel, restaurant, office, etc) rather than fixture count.
 - Refer to Peak Daily Wastewater Flow Estimates By Use for example flow values based on use type, derived from PA Code Title 25 §73.17.
 - Existing Flows will only be considered for active uses within the past ten (10) years.
- PA DEP Sewage Facilities Planning Module Application Mailer
 - Official form number 3800-CD-BCW0359
 - Used by the Authority to evaluate wastewater flows and determine whether Act 537 planning is required.
 - Submission to DEP may not be necessary, but the completed form is required for internal review.
 - Available at the DEP Greenport website (<https://www.depgreenport.state.pa.us/>) or by searching the form number.

Optional Submission Materials (include as applicable):

- Development site plans
- Historical correspondence with the Authority or DEP
- Any other materials supporting the wastewater projections or planning determination

Peak Daily Wastewater Flow Estimates By Use

Type of Use	Peak Daily Flow (gpd)
Apartment, 1-bedroom	150
Apartment, 2-bedroom	300
Apartment, 3+ bedrooms	400
Beauty Shops (per customer chair)	200
Campgrounds w/ utility hookups (per space)	100
Church (per seat)	3
Fairgrounds and Parks w/ restrooms (per person)	5
Hospitals (per bed space)	300
Hotel / Motel (per unit)	100
Laundries, self service (per washer)	200
Mobile Home Parks (per space)	400
Office (per employee)	10
Restaurant w/ drive thru (per patron)	6
Restaurant w/ table service & liquor license (per patron)	12
Restaurant w/ table service (per patron)	10
School (per person)	15
School w/ cafeteria & shower facilities (per person)	25
School w/ cafeteria (per person)	20
Single Family Dwelling (add'l bedrooms)	100
Single Family Dwelling (up to 3 bedrooms)	400
Swimming Pools (per person)	10

Section C: Certification

I hereby certify that the information provided in this Development Information Form, including all supporting documents and calculations, has been prepared in good faith and to the best of my knowledge. I understand that the Washington-East Washington Joint Authority will rely on this information to evaluate wastewater estimations, planning requirements, and that the submission of false or misleading information may alter or invalidate the Authority's determinations if discovered.

Name (Print): _____

Title: _____

Organization: _____

Signature: _____

Date: _____